

CREDIT CATEGORY: Innovation in Design

CREDIT NAME: 1.1 - Pilot Credit - Bird Collision Deterrence

INTENT

Reduce bird injury and mortality from in-flight collisions with buildings.

REQUIREMENTS

Comply with the building façade and site structures, exterior lighting and performance monitoring plan requirements in the attached PDF.

TECHNICAL ADVICE:

[Project name] contains no glazing. All site elements are opaque. Horizontal window louvers are less than 2" apart, but there is no window behind them anyway. The building's railings and façade might encourage birds to interact with the structure, but no BCT values above 15 were identified in any façade. All plans and elevations are uploaded in the project information section. No additional uploads are included or required to meet credit requirements.

There is no decorative lighting, that is to say, no non-safety, entry or circulation lighting that will be on at night, so no additional lighting documentation is needed to meet credit requirements. If the reviewer would like more information on light trespass, please see the light trespass credit.

The [building owner's] incident reporting plan has been uploaded to satisfy the remaining documentation requirements for this credit.