



OVERALL PLAN KEYNOTES: REFER TO SPECIFICATION FOR ADDITIONAL INFORMATION. ALL NOTES MAY NOT APPLY TO THIS SHEET.

2.9	BIKE RACK	5.1	PRE-FINISHED MTL. GUARDRAIL	7.3	CONTROL JOINT	8.1	ALUMINUM STOREFRONT SYST. DARK BRONZE ANODIZED FIN.
3.1	ARCHITECTURAL FINISH CONCRETE	5.2	PRE-FINISHED MTL. GUARDRAIL	7.4	PRE-FINISHED MTL. PARAPET CAP	8.2	ALUMINUM WINDOW SYST.
3.2	CONC. TRANSFORMER PAD	5.3	MTL STAIR	7.5	RIGID INSULATION	8.3	ALUMINUM WINDOW WALL SYST. DARK BRONZE ANODIZED FIN.
3.3	SEALED CONCRETE	5.4	MTL BOLLARD	7.6	WATERPROOF MEMBRANE	8.4	ALUMINUM CURTAIN WALL SYST. DARK BRONZE ANODIZED FIN.
3.4	CONCRETE TOPPING	5.5	STAINED WOOD RAIL	7.7	TPO ROOFING SYSTEM	8.5	PAINTED HOLLOW MTL DOOR
3.5	SPECIAL CONCRETE FLOOR FINISH	6.1	FIBER CEMENT BOARD RAIN SCREEN SYST. OVERFLOOR METAL SCUPPER PER SMACNA SCUPPER DESIGN & INSTALLATION	7.8	TRAFFIC COATING	8.6	PRE-FIN. MTL LOUVER
3.6	SUMP PIT	7.1		7.9	WALKWAY PADS	8.7	UNFRAMED MIRROR
3.7	CONCRETE CURB STOPS	7.2		7.10	ROOF HATCH	8.8	ROLLING COUNTER DOOR
				7.12	PREFIN. METAL ROOF	8.9	AUTOMATIC DOOR OPENER-ADA
						8.10	

WINDOW AND DOOR NOTES:

- GLAZING SHALL BE TEMPERED AS REQUIRED PER 2003 IBC AT LOCATIONS DESCRIBED UNDER SECTION 2406.3.
 - "T" = TEMPERED GLASS. REFER TO SPEC FOR ALL OTHER GLASS TYPES.
 - "F" = INDICATES FIXED WINDOW OR DOOR.
 - REFER TO SPECS FOR HARDWARE GROUPS LISTED ON DOOR SCHEDULE.
- | | | | |
|------|----------------------------|-------|-----------------------------|
| 10.2 | FIRE EXTINGUISHER CABINET | 22.7 | ROOF DRAIN, RE: PLUMB. |
| 10.3 | KNOX BOX | 22.8 | FLOOR DRAIN, RE: PLUMB. |
| 10.4 | FIRE DEPARTMENT CONNECTION | 22.9 | FLOOR SINK. |
| 10.5 | POSTAL BOXES | 22.10 | HOSE BIB |
| 11.1 | TRASH COMPACTOR, N.I.C. | 22.11 | DRINKING FOUNTAIN |
| 13.1 | ACCESS CONTROL SYSTEM | 23.1 | ROOF MOUNTED MECH EQUIPMENT |
| 14.1 | ELECTRIC TRACTION ELEVATOR | 23.2 | GREEN SCREEN SYSTEM |
| 14.2 | TRASH CHUTE | 23.3 | SLIDING GATE |
| 21.1 | PUMP TEST HEADER | 23.4 | PTD MTL FENCE |
| 21.2 | STANDPIPE VALVE | 23.5 | PTD MTL GATE |

PLAN GENERAL NOTES:

- DIMENSIONS ARE TO FACE OF STUD, GRIDLINE, FACE OF CONCRETE, FACE OF CMU, OR CENTERLINE OF DOOR U.N.O.
- RE: SHEET A1.05 FOR WALL ASSEMBLIES. REFER TO SHEET A1.06 FOR FLOOR/CEILING TYPES.
- RE: SHEETS A4.01-A4.03 FOR ENLARGED UNIT PLAN DIMENSIONS, WALL TYPES, DOOR SCHEDULE AND DOOR TYPES, ETC.
- DATUMS SHOWN ON PLANS ARE TO TOP OF CONCRETE (U.N.O.).
- DUMPSTERS AND TRASH COMPACTOR NOT IN CONTRACT.
- RE: SHEET A8.01 FOR DOOR SCHEDULE.
- RE: SHEET A9.01 FOR ACCESSIBILITY STANDARDS (MOUNTING HEIGHTS AND CLEARANCES FOR FIXTURES).
- ALL PENETRATIONS IN RATED WALL OR FLOOR ASSEMBLIES MUST BE FIRE CAULKED PER UL LISTINGS. TYPE "X" GWB IS TO BE CONTINUOUS TO UNDERSIDE OF STRUCTURE AT RATED WALLS AND FIRE CAULKED AS REQUIRED BY CODE. TUBS AT RATED WALLS SHOULD BE HELD OFF FACE OF STUD TO ALLOW TYPE "X" GYPSUM BOARD TO RUN CONTINUOUS TO FLOOR.
- LOCATE FIRE EXTINGUISHERS PER APPLICABLE CODE. CORRIDOR CABINETS TO BE RECESSED. ELECTRIC PANELS IN UNITS TO BE RECESSED. CONTINUE TYPE "X" GWB BEHIND ALL CABINETS TO MAINTAIN RATING.
- ALL WALLS TO HAVE SUPP/DEFLECTION TRACK @ HEAD @ UNDERSIDE OF STRUCTURE.
- ALL ENGINEERING OF INTERIOR AND EXTERIOR WALL STUDS IS BY SUB-CONTRACTOR.
- ALL ENGINEERING ASSOCIATED WITH THE LOCATION AND PLACEMENT OF EMBEDS AT PERIMETER SLAB EDGE FOR SUPPORT OF EXTERIOR WALL TO BE PERFORMED BY SUB-CONTRACTOR.