



PLAN/ INTERIOR ELEVATION KEYNOTES: ALL NOTES MAY NOT APPLY TO THIS SHEET. REFER TO SPECIFICATIONS FOR ADDITIONAL INFORMATION

- | | | |
|--|------------------------------|--------------------------|
| (8.1) ALUMINUM STOREFRONT SYST.
MED. BRONZE ANODIZED FIN. | (11.1) DISHWASHER | (22.1) TOILET |
| (8.2) ALUMINUM WINDOW SYST. | (11.2) REFRIGERATOR | (22.2) LAVATORY |
| (8.3) UNFRAMED MIRROR | (12.1) MANUFACTURED CABINETS | (22.3) URINAL |
| (10.1) FIRE EXTINGUISHER CABINET | | (22.4) KITCHEN SINK |
| (10.2) TOILET PARTITION | | (22.5) DRINKING FOUNTAIN |
| (10.3) GRAB BAR | | (22.6) SERVICE SINK |
| (10.4) TOILET PAPER HOLDER | | (26.2) VANITY LIGHT |
| (10.5) PAPER TOWEL DISPENSER | | |
| (10.6) SOAP DISPENSER | | |

PLAN/ INTERIOR ELEVATION GENERAL NOTES:

- REFER TO SHEET A4.0 & A5.0 FOR ADDITIONAL INFORMATION ON FINISHES AND MILLWORK.
- REFER TO SHEETS A4.0 FOR THE ROOM FINISH SCHEDULE
- DIMENSIONS ARE TO FACE OF STUD, GRIDLINE, FACE OF CONCRETE, FACE OF CMU, OR CENTERLINE OF DOOR U.N.O.
- ALL PENETRATIONS IN RATED WALL OR FLOOR ASSEMBLIES MUST BE FIRE CAULKED PER UL LISTINGS. TYPE "X" GWB IS TO BE CONTINUOUS TO UNDERSIDE OF STRUCTURE AT RATED WALLS AND FIRE CAULKED AS REQUIRED BY CODE-TYPICAL.
- LOCATE FIRE EXTINGUISHERS PER APPLICABLE CODE. CORRIDOR CABINETS TO BE RECESSED. ELECTRIC PANELS TO BE RECESSED. CONTINUE TYPE "X" GWB BEHIND ALL CABINETS TO MAINTAIN RATING.
- ALL WALLS TO HAVE SLIP/DEFLECTION TRACK @ HEAD @ UNDERSIDE OF STRUCTURE.
- ALL ENGINEERING OF INTERIOR WALL STUDS IS BY SUB-CONTRACTOR.
- REFER TO A1.1 FOR WALL, DOOR, AND WINDOW TYPES, WINDOW AND DOOR NOTES, AND DOOR AND FRAME SCHEDULE.