



THRESHOLD ATTEMPTED

Points Attempted: 1

ALL OPTIONS

Select one of the following:

- ☒ None of the adhesive or sealant products used on the interior of the building exceed the allowable VOC limit.
- ☐ **VOC Budget:** One or more of the adhesives or sealants used on the interior of the building exceeds the allowable VOC limit.

NO ADHESIVE OR SEALANT PRODUCTS EXCEED THE VOC LIMITS

Table L-5. Flooring Adhesives and Sealants

Product Type	Product Manufacturer	Product Name / Model	Product VOC Content	Allowable VOC Content	Source of VOC Data (letter, cutsheet, MSDS sheet, etc.)	Source of VOC Data Provided
Indoor Carpet Adhesives	Shaw Industries	Carpet tile Adhe	0	50	MSDS	<input checked="" type="checkbox"/>
VCT & Asphalt Adhesives	Armstrong	Adhesive VCT S	49	50	MSDS	<input checked="" type="checkbox"/>
Cove Base Adhesives	Roppe	Adhesive Base	1	50	MSDS	<input checked="" type="checkbox"/>
All products meet allowable VOC content						Yes

Add Row

Delete Row

Table IEQc4.1-1. Non-Flooring Adhesives & Sealants

Product Type	Product Manufacturer	Product Name / Model	Product VOC Content	Allowable VOC Content	Source of VOC Data (letter, cutsheet, MSDS sheet, etc.)	Source of VOC Data Provided
Plastic Foam Substrate Adhesives	John's Manville	Adhesive tape f	49	50	Cutsheet	<input checked="" type="checkbox"/>
Architectural Non-Porous Sealant Primer	USG	Acoustical Seal	15	250	Cutsheet	<input checked="" type="checkbox"/>
Porous Material (Except Wood) Substrate Ac	National Gypsum	Joint compound	2	50	Cutsheet	<input checked="" type="checkbox"/>

Product Type	Product Manufacturer	Product Name / Model	Product VOC Content	Allowable VOC Content	Source of VOC Data (letter, cutsheet, MSDS sheet, etc.)	Source of VOC Data Provided
Structural Glazing Adhesives	Silpro	C-21 All Acrycli	3.3	100	Letter	<input checked="" type="checkbox"/>
Multipurpose Construction Adhesives	Silpro	Masco	0	70	Letter	<input checked="" type="checkbox"/>
Multipurpose Construction Adhesives	Silpro	Slipro 230	0.5	70	Letter	<input checked="" type="checkbox"/>
Multipurpose Construction Adhesives	Silpro	Silpro 220	0.2	70	Letter	<input checked="" type="checkbox"/>
All products meet allowable VOC content						Yes

All adhesives and sealants used on the inside of the weatherproofing system and applied on-site have been included in the tables above.

Signatory: Contractor; June 24,

REQUIRED SIGNATORY

Initial Here:

CONTRACTOR

Percentage of Source of VOC Data provided for items listed in the tables above:

Upload IEQc4.1-1. Provide the source of VOC data for at least 20% of the materials listed in the tables above, by item (not by cost).

Files: 7

ADDITIONAL DETAILS

- ☐ Special circumstances preclude documentation of credit compliance with the submittal requirements outlined in this form.
- ☐ The project team is using an alternative compliance approach in lieu of standard submittal paths.

SUMMARY

IEQ Credit 4.1: Low-Emitting Materials - Adhesives and Sealants
Points Documented: