



OVERALL PLAN KEYNOTES: REFER TO SPECIFICATION FOR ADDITIONAL INFORMATION. ALL NOTES MAY NOT APPLY TO THIS SHEET.

2.9 BIKE RACK	5.1 PRE-FINISHED MTL. GUARDRAIL	7.3 CONTROL JOINT	8.1 ALUMINUM STOREFRONT SYST. DARK BRONZE ANODIZED FIN.	10.2 FIRE EXTINGUISHER CABINET	22.7 ROOF DRAIN, RE: PLUMB.
3.1 ARCHITECTURAL FINISH CONCRETE	5.2 PRE-FINISHED MTL. GUARDRAIL	7.4 PRE-FINISHED MTL. PARAPET CAP	8.2 ALUMINUM WINDOW SYST.	10.3 KNOX BOX	22.8 FLOOR DRAIN, RE: PLUMB.
3.2 CONC. TRANSFORMER PAD	5.3 MTL. STAIR	7.5 RIGID INSULATION	8.3 ALUMINUM WINDOW WALL SYST. DARK BRONZE ANODIZED FIN.	10.4 FIRE DEPARTMENT CONNECTION	22.9 FLOOR SINK
3.3 SEALED CONCRETE	5.4 MTL. BOLLARD	7.6 WATERPROOF MEMBRANE	8.4 ALUMINUM CURTAIN WALL SYST. DARK BRONZE ANODIZED FIN.	10.5 POSTAL BOXES	22.10 HOSE BIB
3.4 CONCRETE TOPPING	5.5 STAINED WOOD RAIL	7.7 TPO ROOFING SYSTEM	8.5 PAINTED HOLLOW MTL. DOOR	11.1 TRASH COMPACTOR, N.I.C.	22.11 DRINKING FOUNTAIN
3.5 SPECIAL CONCRETE FLOOR FINISH	6.1 FIBER CEMENT BOARD RAIN SCREEN SYST. OVERFLOOR METAL SCUPPER PER SMACNA SCUPPER DESIGN & INSTALLATION	7.8 TRAFFIC COATING	8.6 PRE-FIN. MTL. LOUVER	13.1 ACCESS CONTROL SYSTEM	22.12 ROOF MOUNTED MECH EQUIPMENT
3.6 SUMP PIT		7.9 WALKWAY PADS	8.7 UNFRAMED MIRROR	14.1 ELECTRIC TRACTION ELEVATOR	22.13 GREEN SCREEN SYSTEM
3.7 CONCRETE CURB STOPS		7.10 ROOF HATCH	8.8 ROLLING COUNTER DOOR	14.2 TRASH CHUTE	22.14 SLIDING GATE
		7.12 PREFIN. METAL ROOF	8.9 AUTOMATIC DOOR OPENER-ADA	21.1 PUMP TEST HEADER	22.15 PTD MTL. FENCE
			8.10	21.2 STANDPIPE VALVE	22.16 PTD MTL. GATE

WINDOW AND DOOR NOTES:

- GLAZING SHALL BE TEMPERED AS REQUIRED PER 2003 IBC AT LOCATIONS DESCRIBED UNDER SECTION 2406.3.
- "T" = TEMPERED GLASS. REFER TO SPEC FOR ALL OTHER GLASS TYPES.
- "F" = INDICATES FIXED WINDOW OR DOOR.
- REFER TO SPECS FOR HARDWARE GROUPS LISTED ON DOOR SCHEDULE.

PLAN GENERAL NOTES:

- DIMENSIONS ARE TO FACE OF STUD, GRIDLINE, FACE OF CONCRETE, FACE OF CMU, OR CENTERLINE OF DOOR U.N.O.
- RE: SHEET A1.05 FOR WALL ASSEMBLIES. REFER TO SHEET A1.06 FOR FLOOR/CEILING TYPES.
- RE: SHEETS A4.01-A4.03 FOR ENLARGED UNIT PLAN DIMENSIONS, WALL TYPES, DOOR SCHEDULE AND DOOR TYPES, ETC.
- DATUMS SHOWN ON PLANS ARE TO TOP OF CONCRETE (U.N.O.).
- DUMPSTERS AND TRASH COMPACTOR NOT IN CONTRACT.
- RE: SHEET A8.01 FOR DOOR SCHEDULE.
- RE: SHEET A8.01 FOR ACCESSIBILITY STANDARDS (MOUNTING HEIGHTS AND CLEARANCES FOR FIXTURES).
- ALL PENETRATIONS IN RATED WALL OR FLOOR ASSEMBLIES MUST BE FIRE CAULKED PER UL LISTINGS. TYPE "X" GWB IS TO BE CONTINUOUS TO UNDERSIDE OF STRUCTURE AT RATED WALLS AND FIRE CAULKED AS REQUIRED BY CODE. TUBS AT RATED WALLS SHOULD BE HELD OFF FACE OF STUD TO ALLOW TYPE "X" GYPSUM BOARD TO RUN CONTINUOUS TO FLOOR.
- LOCATE FIRE EXTINGUISHERS PER APPLICABLE CODE. CORRIDOR CABINETS TO BE RECESSED. ELECTRIC PANELS IN UNITS TO BE RECESSED. CONTINUE TYPE "X" GWB BEHIND ALL CABINETS TO MAINTAIN RATING.
- ALL ENGINEERING OF INTERIOR AND EXTERIOR WALL STUDS IS BY SUB-CONTRACTOR.
- ALL ENGINEERING ASSOCIATED WITH THE LOCATION AND PLACEMENT OF EMBEDS AT PERIMETER SLAB EDGE FOR SUPPORT OF EXTERIOR WALL TO BE PERFORMED BY SUB-CONTRACTOR.