

ASHRAE 90.1-2004 Classification- Interior Lighting Power Allowance (Space-by-Space Method)			
SPACE TYPE	ASHRAE 90.1 LEED W/SF	AREA	ALLOWANCE (W)
CORRIDOR	0.5	1,810.0	905.0
EXERCISE AREA	0.9	216.0	194.4
LOBBY	1.3	856.0	1,112.8
LOUNGE AREA	1.2	765.0	918.0
MULTI-PURPOSE ROOM/CONFERENCE ROOM/MEETING ROOM	1.3	1,221.0	1,587.3
MULTI-PURPOSE ROOM/CONFERENCE ROOM/MEETING ROOM W/ DECO LTS *	2.3	1,312.0	3,017.6
OFFICES, ENCLOSED & OPEN	1.1	5,368.0	5,904.8
RESTROOMS	0.9	451.0	405.9
STORAGE AREA	0.8	501.0	400.8
TOTALS		12,500.0	14,446.6

* THIS IS 1 WATT ADDITIONAL FOR DECORATIVE LIGHTING AS PER ASHRAE 90.1 SECTION 9.6.3